



Proposed Code Change  
State Form 41186R

RETURN TO:  
INDIANA DEPARTMENT OF HOMELAND SECURITY  
CODE SERVICES SECTION  
302 W. Washington Street Room W246  
Indianapolis, IN 46204

FOR OFFICE USE ONLY

Received 10/13/09

Code 48.8.6.5-09

INSTRUCTIONS:

Only TYPED copy accepted.

(KEY- ~~Dashed line through material to be deleted~~, underline material to be added)

Use second sheet for any material requiring more space.

Code Title <b>Indiana Residential Code</b>		Edition <b>2009</b>
Section number and title <b>Section 404.1.1 Design of Masonry Foundation Walls</b>		Page <b>1</b>
Proponent <b>SW Indiana Builders</b>	and Title <b>Building Officials</b>	
Address <b>2175 N Cullen Ave Evansville, IN 47715 Room 310, Civic Center Complex, Evansville, IN 47708</b>		Phone <b>812-479-6026 &amp; 812-436-7868</b>
PROPOSED CODE CHANGE (Check One)		
<input type="checkbox"/> Change to read as follows <input type="checkbox"/> Add to read as follows <input type="checkbox"/> Delete and substitute as follows <input type="checkbox"/> Delete without substitution		
<b>Delete Section and replace as follows: "Concrete masonry and clay foundation walls shall be constructed as set forth in Tables R404.1.1(1), R404.1.1(2), R404.1.1(3) and R404.1.1(4) and shall comply with the provisions of this section and the applicable provisions of Section R606.1 through R606.10, R607, R608, and R610. Rubble masonry foundation walls shall be constructed in accordance with Sections R404.1.8 and R606.2.2."</b>		
REASON		
<b>This amendment is part of the Seismic Package supported by home builders and building officials in the area, and is consistent to the existing standards. <i>Fiscal impact: As this seismic package is parallel to existing standards, no impact is expected.</i></b>		
REVIEW RECOMMENDATION		
Approve		
Disapprove		
Approve as amended		
Further Study		